

**QUESTIONS AND RESPONSES
FOR
MAINTAIN TURBINE GENERATOR #4
AT
EIELSON AIR FORCE BASE, ALASKA

SOLICITATION NO. FA5004-09-R-C012**

It shall be noted to all interested parties that the following questions have been received in writing regarding the subject acquisition. Additionally, responses have been provided to the below listed questions.

As a reminder, it is the responsibility of all Interested Parties to review this website (<http://www.fedbizopps.gov>) frequently for any updates and/or amendments to any and all subject documents.

Question:

A. Section 15699 Item 3.04 Paragraph RR – Is balance is to be completed onsite? The power requirement would be 480 volts 3 phase 50 amps.

Response:

Balance is to be accomplished on-site. The Government will provide a portable generator/panel for this operation.